



TOWN OF GRAFTON

26 Upton Street

GRAFTON, MASSACHUSETTS 01519

Phone: (508) 839-4606 • FAX: (508) 839-8520

Michael E. Gauthier
Fire Chief

December 10, 2018

Charles Kady
129 Charlton Rd
Spencer, MA 01562

Ref: Determination of Completeness
Desrosier Landing, South Grafton, MA

To Whom It May Concern:

All structures within this development are required to be equipped with a hardwire Fire Detection System and CO detection.

Fire Department compliance inspections for residential subdivisions are done for each structure at the time occupancy is requested for that building. These inspections include Street signs, House numbers, Fire Detection Systems (Smoke detectors, Heat detectors, and CO detectors) Oil Heating Systems, Propane Storage. A structure would not pass its occupancy inspection without all of the above being in place.

My inspection review of the finish conditions of the hydrant system shows that it appears to have been constructed according to plans that were approved on 6/2/2009

This development has satisfied all Fire Department requirements.

Sincerely,

A handwritten signature in cursive script that reads "Stephen L. Charest".

Stephen L Charest, *Asst. Chief*